

Flint Community Schools Testing Results - Initial Screen

October 2, 2015

ANALYTE	RESULT (mg/L)	Address	Sample Description	Collection Date
Lead	0.004	1040 N SAGINAW ST	3RD FLOOR CAFETERIA	02-Oct-15
Lead	0.007	1040 N SAGINAW ST	1ST FLOOR FTN	02-Oct-15
Lead	0.009	1040 N SAGINAW ST	2ND FLOOR LOWER FTN	02-Oct-15
Lead	0.001	1101 W VERNON DR PIERCE ELEMENTARY	CUSTODIAN OFFICE DRINKING FOUNTAIN	02-Oct-15
Lead	0.003	1101 W VERNON DR PIERCE ELEMENTARY	None Provided	02-Oct-15
Lead	0.008	1101 W VERNON DR PIERCE ELEMENTARY	DRINKING FOUNTAIN MAIN HALL	02-Oct-15
Lead	0.009	1420 W TWELFTH	DRINKING FOUNTAIN	02-Oct-15
Lead	0.015	1420 W TWELFTH	DRINKING FTN BY RM 3	02-Oct-15
Lead	0.007	1420 W TWELFTH ST	ACROSS FROM CAFETERIA DRINKING FTN	02-Oct-15
Lead	0.005	1518 UNIVERISTY AVE	GYM/POOL DRINKING FTN	02-Oct-15
Lead	0.001	1518 UNIVERSITY AVE	3RD FLOOR FOUNTAIN	02-Oct-15
Lead	0.002	1518 UNIVERSITY AVE	2ND FLOOR FOUNTAIN	02-Oct-15
Lead	0.001	2010 CRESTBROOK SCHOOL	LOWER DRINK FTN	02-Oct-15
Lead	0.002	2010 CRESTBROOK SCHOOL	HIGH DRINK FTN	02-Oct-15
Lead	0.001	2500 N AVERILL SCHOOL	HIGH DRINK FTN SO ENTRANCE	02-Oct-15
Lead	Not detected	2500 N AVERILL SCHOOL	HIGH DRINK FTN ACROSS FRM TEACH	02-Oct-15
Lead	0.004	305 WALNUT ST	KITCHEN FOOD PREP SINK	02-Oct-15
Lead	0.006	305 WALNUT ST	DRINKING FTN	02-Oct-15
Lead	0.009	305 WALNUT ST CENTRAL KITCHEN	KITCHEN FOOD PREP	02-Oct-15
Lead	0.002	923 E KEARSLEY	1ST FL DRINK FTN	02-Oct-15
Lead	0.005	923 E KEARSLEY	2ND FL BTN 207 & WMS RSTRM	02-Oct-15
Lead	0.003	923 E KEASLEY ADMIN	BASEMENT ADMIN	02-Oct-15
Lead	0.002	BROWNELL S T E M ACADEMY	DRINK FOUNTAIN ROOM 12	02-Oct-15
Lead	0.005	BROWNELL S T E M ACADEMY	DRINK FTN GYM BATHRM	02-Oct-15
Lead	0.031	BROWNELL S T E M ACADEMY	DRINK FOUNTAIN RM 6 & 7	02-Oct-15
Lead	0.003	EISENHOWER ELEMENTARY	FOUNTAIN GYM	02-Oct-15
Lead	0.016	EISENHOWER ELEMENTARY	FOUNTAIN ROOM 209	02-Oct-15
Lead	0.028	EISENHOWER ELEMENTARY	FOUNTAIN ROOM 102	02-Oct-15
Lead	0.003	FREEMAN ELEMENTARY	FOUNTAIN NORTH END OF BLDG	02-Oct-15
Lead	0.008	FREEMAN ELEMENTARY	FOUNTAIN MIDDLE AT SCHOOL	02-Oct-15
Lead	0.101	FREEMAN ELEMENTARY	FOUNTAIN SO END OF BLDG	02-Oct-15
Lead	0.002	HOLMES S T E M ACADEMY	DRINK FOUNTAIN D114	02-Oct-15
Lead	Not detected	HOLMES S T E M ACADEMY	DRINK FOUNTAIN BLUE HALLWAY C109	02-Oct-15
Lead	Not detected	HOLMES S T E M ACADEMY	DRINKING FOUNTAIN OFFICE	02-Oct-15
Lead	0.002	NORTHWESTERN HIGH SCHOOL	DRINKING FTN LIBRARY NORTH	02-Oct-15
Lead	0.004	NORTHWESTERN HIGH SCHOOL	DRINK FOUNTAIN CAFE WEST	02-Oct-15
Lead	0.010	NORTHWESTERN HIGH SCHOOL	DRINK FTN LIBRARY SOUTH	02-Oct-15